AU/AU/RA

RECEIVE

ExxonMobil Chemical Company

5000 Bayway Drive P.O. Box 4004 Baytown, Texas 77522-4004 Extered into Consenter 4-01-13 DUL

MMR 25 20.3

Air/Toxics & Inspection Coordination Branch 6EN-A

ExonMobil

Chemical

March 21, 2013

Mr. John Blevins Director, Compliance and Enforcement Division US EPA, Region 6 1445 Ross Ave. **Suite 1200** Mail Code 6 EN Dallas, TX 75202-2733

Re: Equivalency Determination Request Multi-Point Ground Flare (MPGF) **Baytown Olefins Plant & Mont Belvieu Plastics Plant**

Dear Mr. Blevins:

ExxonMobil Chemical Company (ExxonMobil) requests an equivalency determination pertaining to the requirements of 40 CFR §60.18 and 40 CFR §63.11 as related to multi-point ground flares (MPGF) proposed as part of expansion projects occurring at two facilities - ExxonMobil's Olefins Plant in Baytown, Texas (referred to as Baytown Olefins Plant or BOP) and the ExxonMobil Plastics Plant in Mont Belvieu, Texas (referred to as Mont Belvieu Plastic Plant or MBPP). The proposed BOP MPGF will control waste gases from a new ethylene unit, and the proposed MBPP MPGF will control waste gases from a new polyethylene unit. Source-specific information on the new ethylene and polyethylene units is provided in Attachment 1 to this letter.

The two MPGFs are similar in purpose, design, and operation. Both flares will be designed as an integral part of a larger control system that will control waste gases in stages. At both facilities, waste gases are directed to a vent collection system comprised of two separate dispositions: a High Pressure (HP) disposition and a Low Pressure (LP) disposition. Simplified schematics depicting the control systems for the vent collection systems are provided as Figures 2-1 and 2-2 of Attachment 2 to this letter.

For both sites, the LP disposition will include an elevated flare that will comply with 40 CFR §60.18 and/or 40 CFR §63.11 (as applicable). The majority of waste gas flow is anticipated to be routed to the LP dispositions. Waste gases are only anticipated to be routed to the MPGF above a set pressure. Each MPGF is itself a multi-staged flare system designed to operate with multiple pressure-assisted burners to facilitate the optimal mixing of the combustion materials, in lieu of any assist medium like air or steam, in order to maintain consistent flame stability and proper combustion. The MPGF's design utilizes the kinetic energy inherent within the high pressure relief gas to passively entrain sufficient quantities of combustion air resulting in flare tip exit velocities that will exceed V_{MAX} as specified in 40 CFR §60.18(c)(3),(4) or 40 CFR 63.11(b)(6),(7),(8). A detailed technical description of the complete multistaged flare system is provided in Attachment 2 to this letter.

Equivalency Determination:

Based on the information provided above and in the technical attachments noted, ExxonMobil hereby requests formal written approval to comply with 40 CFR §60.18 and/or 40 CFR §63.11(b) (as applicable) at its facilities using similar flare devices in an equivalent manner as specified here:

- 1. The MPGF is provided with a performance guarantee from a manufacturer that it has been designed for smokeless operation over its entire pressure operating range. As such, it will be operated as specified in 40 CFR §60.18(c)(1) and 40 CFR §63.11(b)(4), to be determined as specified in 40 CFR §60.18(f)(1) and 40 CFR §63.11(b)(4), if applicable.
- 2. To comply with 40 CFR §60.18(c)(2), or if applicable with §63.11(b)(5), the MPGF will be operated with at least one pilot flame present at all times for each row of operating burners in a line (called a 'runner'). The pilot burner is generally located within the first three burners in a row for each runner. These burners serve as subsequent ignition points for the remaining burners in the same row. There shall be several such runners that will be opened or closed based on the flare gas flow to the MPGF. Thermocouples or equivalent devices will be used to monitor for presence of a pilot flame. Since the overall flare system is staged, there will be no routine flame present from the MPGF burners themselves if vent gas pressure remains below the set point.
- 3. To comply with 40 CFR §60.18(c)(3), or if applicable with 40 CFR §63.11(b)(6), a minimum net heating value of no less than 800 British thermal units per standard cubic foot (Btu/scf) will be maintained for the gases being combusted at the MPGF. The net heating value of the waste gases to the MPGF will be monitored when waste gas is being directed to the MPGF using either calorimetry or gas chromatography (GC).
- 4. A permanent waiver is requested for the exit velocity requirements of 40 CFR §60.18(c)(3),(4), or if applicable 40 CFR §63.11(b)(6),(7),(8), and the corresponding determination requirements of 40 CFR §60.18(f)(4) or if applicable 40 CFR §63.11(b)(7), for each MPGF.
- 5. A permanent waiver from 40 CFR §60.18(c)(6) and 40 CFR §63.11(b)(2) is requested as the MPGFs are pressure assist and not steam, air, or non-assist flares.
- 6. Per 40 CFR §60.8(b)(4) or 40 CFR §63.7(e)(2)(iv), a permanent waiver is requested from the performance test or flare initial compliance assessment to demonstrate compliance with 40 CFR §60.18 or 40 CFR §63.11 as allowed by agency consideration. Waste gases to the MPGF are anticipated to be from large flows of short duration. Replicating the operational scenarios that would generate these large waste gas streams for the amount of time required for testing is impractical and could pose significant safety concerns in terms of data collection. Additional supporting information for this request is provided in Attachment 3 to this letter.
- 7. Lastly, ExxonMobil proposes additional and alternative monitoring techniques of the vent gas flow according to the manufacturer's recommendation to ensure only high pressure vent gases are routed to the MPGFs. These are proposed as alternative monitoring procedures per 40 CFR §60.13(i) and 40 CFR §63.8(f)(4). The proposed monitoring parameters and how they meet the four criteria elements of the 40 CFR §63.2 definition of monitoring is provided in Attachment 4 to this letter.

ExxonMobil is eager to discuss this request for an Equivalency Determination. If you have any questions about the information provided, please contact Benjamin Hurst at benjamin.m.hurst@exxonmobil.com or (281) 834-6110.

Sincerely,

Benjamin M. Hurst

Air Advisor

ExxonMobil Chemical Company

Enclosures

cc: Manager, TCEQ Region 12 Air Program, Houston

Source Information

Baytown, TX Source

In May 2012, the ExxonMobil BOP located in Baytown, Harris County, Texas submitted a New Source Review (NSR) application to the Texas Commission on Environmental Quality (TCEQ), as well as a Greenhouse Gas (GHG) Prevention of Significant Deterioration (PSD) application to the EPA, for authorization of construction and operation of a new BOP ethylene unit. The new unit will consist of eight new ethylene cracking furnaces and associated recovery equipment. The recovery equipment include a quench tower, caustic wash facilities, a process gas compressor and interstage coolers, chiller train, refrigeration system, deethanizer, ethylene/ethane splitter, and demethanizer. The process is depicted in Figure 1-1.

The requirements of federal New Source Performance Standards (NSPS), Nation Emission Standards for Hazardous Air Pollutants (NESHAP), and/or NESHAPs for Source Categories (MACT) are potentially applicable to the proposed new equipment. Emissions control standards under potentially applicable regulations (e.g., in 40 CFR Part 60, Subpart NNN (NSPS NNN) and Subpart RRR (NSPS RRR); 40 CFR Part 63, Subpart YY (Ethylene MACT), etc.) require that any flare used to control waste gas from subject equipment must comply with 40 CFR §60.18 (NSPS/NESHAP) or 40 CFR §63.11 (MACT) through performance testing in 40 CFR §60.8 (NSPS/NESHAP) or 40 CFR §63.7 (MACT). The waste gases from the proposed new equipment will be controlled, in part, by a new MPGF. The MPGF is described in Attachment 2 to this letter.

In addition to federal regulation, the MPGF will be subject to monitoring requirements under Title 30 of the Texas Administrative Code (30 TAC) Chapter 115, Subchapter B for volatile organic compounds, and Subchapter H for highly-reactive volatile organic compounds, as well as State NSR permit requirements (anticipated to be in Air Quality Permit No. 102982). Both 30 TAC Chapter 115 and the NSR permit (anticipated) refer back to the federal standards within 40 CRF §60.18. Due to the unique design of the proposed MPGF, the TCEQ rules allow the submittal of an Alternative Means of Control request for the MPGF, which was submitted in December 2012, and contains the same monitoring procedures as are proposed within this equivalency determination request.


Mont Belvieu, TX Source


In May 2012, the ExxonMobil MBPP located in Mont Belvieu, Chambers County, Texas, submitted an NSR application to the TCEQ, as well as a GHG PSD application to the EPA, for authorization of construction and operation of a new MBPP polyethylene ethylene unit. The new unit will be used to produce polyethylene in low-pressure, gas-phase fluidized bed reactors. Catalyst, monomer, co-monomer, and inert chemicals are fed to the reactors. The polymer produced by the reactors is in the form of granules suspended by circulating gases. Product from the reactors goes through a series of polymer separation and purging stages, and is ultimately extruded into pellets. The pellets are transferred to storage silos and are packed in bags and containerized for shipping. The process is depicted in Figure 1-2.

The requirements of federal New Source Performance Standards (NSPS), Nation Emission Standards for Hazardous Air Pollutants (NESHAP), and/or NESHAPs for Source Categories (MACT) are potentially applicable to the proposed new equipment. Emissions control standards under potentially applicable regulations (e.g., in 40 CFR Part 60, Subpart DDD (*NSPS DDD*); 40 CFR Part 63, Subpart FFFF (MON *MACT*), etc.) require that any flare used to control waste gas from subject equipment must comply with 40 CFR §60.18 (NSPS/NESHAP) or 40 CFR §63.11 (MACT) through performance testing in 40 CFR §60.8 (NSPS/NESHAP) or 40 CFR §63.7 (MACT). The waste gases from the proposed new equipment will be controlled, in part, by a new MPGF. The MPGF is described in Attachment 2 to this letter.

In addition to federal regulation, the MPGF will be subject to monitoring requirements under 30 TAC Chapter 115, Subchapter B for volatile organic compounds, and Subchapter H for highly-reactive volatile organic compounds, as well as permit requirements State NSR permit requirements (anticipated to be Air Quality Permit No. 103048). Both 30 TAC Chapter 115 and the NSR permit (anticipated) refer back to

the federal standards within 40 CFR §60.18. Due to the unique nature of the proposed MPGF, the TCEQ rules allow submittal of an Alternative Means of Control for the MPGF, which was submitted in December 2012, and contains the same monitoring procedures as are proposed within this equivalency determination request.





Flare Systems

Technical Description

The Baytown Ethylene Expansion and Mont Belvieu Plastics Plant Expansion projects will include "staged" control systems which will include a MPGF (Multi-Point Ground Flare). The MPGF will be manufactured by an industry leader in flare technology, such as the John Zink Company (manufacturer of the LRGO multi-point flare system). The control systems are described as "staged" because they are designed to ensure that streams are controlled appropriately based on operating conditions. Figures 2-1 and 2-2 are simplified schematics depicting the control systems for the vent collection systems for the expansions at BOP and MBPP, respectively. ExxonMobil seeks advanced authorization and approval to demonstrate equivalency prior to when the proposed new ground flare would be required to comply with 40 CFR §60.18, or 40 CFR §63.11 (i.e., approval is desired prior to start-up).

The MPGFs will control VOC emissions during the high pressure / high flow occasions. The MPGF technology has a principle application to the petroleum refining and chemical processing industries due to its staging systems that ensure short, smokeless flames maintained over the full operating range of the flare. The burner design utilizes pressure to assist combustion of waste gas by entraining an adequate amount of ambient air. Pressure-assisted flares are viewed by combustion experts as among the highest destruction and removal efficiency (DRE) flares available. Requirements in 40 CFR §60.18 and 40 CFR §63.11 limit the heating value and exit velocity of the waste streams routed to applicable flares to ensure the design and operation of these flares achieve the required destruction efficiency with the benefits of their particular assist methods. Background information that was used to establish the heating value and exit velocity for 40 CFR §60.18 and 40 CFR §63.11 does not include MPGF systems, and therefore, the limit of maximum exit velocity should not apply to the proposed MPGFs. Establishing a minimum heating value combined with stable flame design will ensure good combustion of the waste gas at the flare tip. Limiting the exit velocity would impact the pressure-assisted burner by preventing it from reaching its critical pressure (hence preventing from entraining adequate amount of air for mixing and proper combustion), and would not allow the flare to operate at its design conditions.

The proposed MPGFs will use a fixed position array of high pressure burners within a secure fenced area to produce short, highly efficient open-air flames. Pressure-assisted burners utilize the flare gas pressure to ensure high exit velocity at the burner exit. The high velocity produces the energy required to promote high air entrainment and mixing in the combustion zone. This entrainment / mixing energy in the combustion zone is the key to producing an efficient, smokeless flame. This energy level is created by a high velocity discharge without requiring supplemental energy such as steam or forced air blowers. The philosophy of the control system provides that when gas (energy) flow is low, the number of burners is reduced in order that there is sufficient fuel supply to each burner to maintain the required energy level for clean burning.

The MPGFs will be designed with multiple headers, each header having multiple risers with burners. The burners will be designed such that a number of small diameter ports eject high velocity gas, enhancing air entrainment and mixing for efficient and clean combustion. The aerodynamics of the burners provides air cooling and prevents flame recirculation, eliminating burner over-heating and internal coking. The staging control system, which can be either programmable logic controller (PLC) or distributed control system (DCS) based, will receive input from pressure transmitters and open and close staging valves according to waste gas pressure. Each stage will be operated automatically with an actuated valve that opens or closes upon demand.

MPGF at Baytown, TX Source:

The flare system for the Baytown Ethylene Expansion unit project will include a "staged" control system that will consist of an elevated flare and a MPGF (Multi-Point Ground Flare). The control system is described as "staged" because it is designed to ensure that streams are controlled appropriately based on operating conditions. The vent collection system feeding the control system is comprised of one common header. Figure 2-1 is a simplified schematic depicting the control system for the vent collection system.

ExxonMobil Equivalency Determination Request The common flare header will receive routine continuous vent streams and routine intermittent vent streams from the process. The streams which make-up less than 1% of the MPGF rated capacity will be controlled by the steam-assisted elevated flare. The common header will operate at low pressure, until the rate through the common flare header exceeds the capacity of the steam assisted elevated flare (equivalent to 1% of the MPGF capacity). A performance test / flare initial compliance assessment will be conducted for the elevated flare, and it will be operated in accordance with 40 CFR §60.18 and/or 40 CFR §63.11.


When the total rate through the flare header exceeds the capacity of the elevated flare, a control valve will limit the rate to the elevated flare to that of its design, and divert any excess flow to the MPGF. When the back pressure in the flare header rises to the design pressure, the first staging valve of the MPGF opens. This may occur during defined periods of unit purging for shutdowns or startups. The flare system computer control application ensures that the MPGF is operated only at times when the header meets the design conditions.


MPGF at Mont Belvieu, TX Source:

The MPGF will be part of a "staged" control system that will consist of flameless thermal oxidizers (FTOs), an elevated flare, and the MPGF. The control system is described as "staged" because it is designed to ensure that streams are controlled appropriately based on operating conditions. The vent collection system feeding the control system is comprised of two separate headers: a High Pressure (HP) Vent Header and a Low Pressure (LP) Vent Header. Figure 2-2 is a simplified schematic depicting the control system for the vent collection system.

The LP Vent Header will receive routine continuous vent streams and routine intermittent vent streams from the process. The streams are also referred to as "low volume, low pressure" (LVLP) streams, and will be controlled by FTOs and an elevated flare assisted by either steam or air. The HP Vent Header is designed to receive high load, short duration vent streams, also referred to as "high volume, high pressure" (HVHP) vent streams. The control device that will control emissions on the HP Vent Header is the proposed MPGF. A performance test/flare initial compliance assessment will be conducted for the elevated flare, and it will be operated in accordance with 40 CFR §60.18 and/or 40 CFR §63.11.

The two separate headers (HP and LP) are connected through a spill-over line with a HP to LP valve controlled by a computer control application which is used to direct the flow away from the HP header system. This may occur during defined periods of unit purging for shutdowns or startups. This computer control application will also divert flow from the HP Vent Header to the LP Vent Header upon instances when the HVHP vent does not have adequate operating pressure. This computer control application ensures the MPGF is operated only at times when the HP Vent Header meets the design conditions.





Performance Test Waiver Supporting Information

Performance Testing

Applicable 40 CFR Subparts require performance testing under 40 CFR §60.8 and 40 CFR §63.7. Performance test requirements per 40 CFR §60.8(b) and 40 CFR §63.7(e)(2)(iv) are as follows:

Performance tests shall be conducted and data reduced in accordance with the test methods and procedures contained in each applicable subpart unless the Administrator (1) specifies or approves, in specific cases, the use of a reference method with minor changes in methodology, (2) approves the use of an equivalent method, (3) approves the use of an alternative method the results of which he has determined to be adequate for indicating whether a specific source is in compliance, (4) waives the requirement for performance tests because the owner or operator of a source has demonstrated by other means to the Administrator's satisfaction that the affected facility is in compliance with the standard...

Given that the MPGF's fundamental design for enhanced ambient air entrainment relies on high flare tip exit velocities, demonstrating velocities below the V_{MAX} during the performance test would not show proper operation of the control device. The heating value of the waste gas is related to proper operation and will be continuously monitored as described in Attachment 4 to this letter. Stable, smokeless flames and high destruction efficiency will be continuously ensured during the MPGF's operation. This is considered equivalent to meeting 40 CFR §60.18 and 40 CFR §63.11, and thus, a waiver from testing is requested. Please note also that the waste gas controlled by the MPGF are expected to result from large flows of short duration. Replicating the operational scenario that would generate HVHP streams for the amount of time required for testing is impractical and could pose safety concerns.

Furthermore, testing of the burners is considered unnecessary given that destruction efficiency evaluation data is available for similar ground flares. The EPA Air Pollution Control Cost Manual, 6th Ed., acknowledges that pressure-assisted flares use high vent gas pressure to promote mixing at the burner tip, and the EPA has been involved with or aware of the following studies which report DRE results:

- o Flare Efficiency Study, EPA Document No. 600/2-83-052, July 1983
- Evaluation of the Efficiency of Industrial Flares: Flare Head Design and Gas Composition,
 EPA Document No. 600/2-85-106, September 1985
- o Varner et al., 2007, Docket ID No. EPA-HQ-OAR-2010-0868

Table 4 (attached) of EPA Document No. 600/2-83-052 shows an array of > 99% combustion efficiency results for tests where the exit velocity exceeds V_{MAX} . Furthermore, test numbers 1-5, 7, 8, and 67 demonstrate that, at high exit velocities and high lower heating values, combustion efficiencies \geq 99.8% are expected. Testing conducted by John Zink specifically for linear relief gas oxidizer (LRGO) burners and provided to EPA demonstrate similar results with an overall combustion efficiency of 99.82% (also attached). The burners for the MPGF in this equivalency determination request will be the same or similar to the burners tested

In the referenced testing, propylene mixtures were used to demonstrate performance. Propylene's high Btu content makes it comparable to the composition of the streams that will be combusted in the proposed MPGFs. However, in other regards, propylene is a conservative stream to test DRE in a pressure-assist system because ethylene has a more stable flame (i.e., wider flammability range, higher burning velocity, and lower ignition temperature) than propylene. Thus, propylene would result in lower tested combustion efficiencies than ethylene.

Conclusion

Because sufficient test data demonstrating the performance of the proposed burners is readily available, no further testing is proposed. Furthermore, John Zink has guaranteed performance of the MPGFs' burners over the operating envelope discussed in Attachment 4 and as documented in Attachment 5.

TABLE 4. STEAM-ASSISTED FLARE SUMMARY

§	Test Conditions Test Mumber	Flow (SCFN)	Exit Welority (ft/min) 2,523	Lower Heating Value (8tu/SCF)	RELIEF GAS* Propylene Flow [lbs/hr] (SCFM) 3,138 473	1 .1	Nitrogen Flow (SGFN)	(SCFN)	Steam Flow (1bs/hr) 2,159	Steam-to-Aelief Gas Ratio (1b/tb) 0.688	Combustion Efficiency Percent
	• ≈ 4,	464	2,475	2,183	3,078	494	,	•	1,564	0.508	99.82
	m	426	2,432	2,183	3,027	465	•	•	1,355	0.448	99.85
	₹ '	283	1,509	2,183	1,875	£83	•	•	•	•	-08-36
	∞ ~	. 157 154	637 8 21	2,183 2,183	1,044 1,019	154	• •		722	0.757	28.81 29.84
	· vo	149	795	2,183	166	348	ı	•	3,543	1.56	99.94
	19	748	789	2,183	980	148	,	1	111	0.725	See pg. 28.
1	17	24.5	131	2,183	162	24.5	•	1	350	0.926	99.64
	æ	24.4	130	2,183	162	24.4	•		88	3.07	99.45
=	essive 56	24.5	131	2,183	163	24.5			295	3.45	99.30
= =	Steam Flow	0.25	133	2,183	166	25.0	•	7	¥;	[9.6]	82.18
	<u> 56</u>	24.7	132	2,183	164	24.7	•	17.7.4	1,128	6.86	68.95
1	57	703	3,749	294	629	94.8	2,663	\$5. £ 809	765 7	0.150	99.90
	11(a)	999	3,520	305	61 2	92.2	2,489	3.4× 895	, •	•	99.93
	11(b)	599	3,195	342	623	93.9	2,210	198 A 80 E	1 4	•	99.86
	11(c)	929	2,965	364	919	92.8	2,028	463 30	- 4.00	•	99.82
	59(4)	591	3,152	192	345	25	2,361	539 (4		•	98.11
	29(p)	495	2,645	232	320	52.7	1,942	443 - 5	•	•	99,32
	9	334	1,781	8	212	35	1,325	302 14	•	•	28:35
	53	325	1,733	308	305	4 6	1,222	279 25	952	0.168	99.66
	16(a)	320	1,707	339	329	49.6	1,162	270 27	27.8	•	99.74
	16(6)	252	1,344	408	313	47.2	697	202 34	34.9	•	99.75
	16(c)	194	1,035	619	307	46.2	9		- 2.24	•	99.74
•	16(d)	159	848	634	30,	46.3	496	113 62		•	99.78
ı	52	0.356	1.90	602	0.226	0.0341	. 1.41	0.322		t	98.90
	, 23	0.494	2.63	267	0.451	0.0680	2.13	0.487	•	•	100.001
-	Excessive (52	0.556		592	0.452	0.0682	2.14	0.488	102	77.5	98.85
٠						1 1 1	•				

^{*} All values at standard conditions of 20^{0F} and 29.92 in Mg.

^{**} Not accounting for carbon present as soot (see Table 10).

^{***} for purge flows the pilot contributed greater than 95% of the total combustible gas to the flare.



4401 South Peoria Avenue Tulsa, Oklahoma 74105 918/747-1371 Telex 497414

February 17, 1984

U.S. Environmental Protection Agency Research Traiangle Park, NC 27711

Attention: Leslie Evans

Chemical Process Branch

Gentlemen:

Please find enclosed data from LRGO tests conducted at John Zink Company on June of 1982. ES-Test No. 81 covers a John Zink LRGO firing 2,800 lb/hr of crude propylene on an LRGO burner with 1.312 sq. in. orifice area. The propylene temperature was 150°F.

We trust this information will be of assistance in your efforts to determine LRGO efficiency. Please advise if we can be of further assistance.

Yours truly,

JOHN ZINK COMPANY

F CHESTAN

MK/tac Enclosure

3109 NORTH INTERREGIONAL • AUSTIN, TEXAS 78722 • 512/477-9901

CABLE ADDRESS: ENGINSCI TELEX: 77-6442

November 12, 1982

Mr. Roger Noble John Zink Company 4401 S. Peoria Tulsa, Oklahoma 74105

Dear Roger:

This letter is in response to your inquiry regarding the analytical methods used to determine the emissions from several JZ flares tested by Engineering-Science, Inc., on June 30 and July 1, 1982. The analysis techniques and quality assurance activities employed for these tests were the same as those used by ES to conduct a series of flare efficiency tests for the U. S. Environmental Protection Agency (EPA) and the Chemical Manufacturers Association (CMA) in June

The details of the test protocol are detailed in a report prepared by ES and provided to EPA and CMA entitled, "A Report on a Flare Efficiency Study". Copies of this report are available from:

Chemical Manufacturers Association 2501 M Street N.W. Washington, D.C. 20037 202/887-1100

Enclosed is a diagram from this report that summarizes the flare sampling and analysis system.

Sincerely.

Marc D. McDonel Project Manager

Encl.

/kq

TEST B1 TEST DATA SUMMARY (BACKGROUND CORRECTED)

(;

CBAC	
	99.82%
	11
	EFFICIENCY
÷	OVERALL COMBUSTION EFFICIENCY =
	OVERALL

_	TIME	PROBE HGT(FT)	PROBE TEMP(C)	202	202	РРЖ.			02	25	Ş	1000	
)	10,10,01,01			3 6	V22	03	C02	750	(X)	(MPH)	(DEG)	TEMP(C)	ν Ε Ε
	? *	37:00	157.7		2.05	9•0	2867.	-1.1	20.85		1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1		
)	30/18:01:58	37:00	, ,,	0-016	9-16		5037.	-1.2	20.30	9	183.	36.52	100.02%
	:05:1	37:00		006	1.50	1.7	4112	-1-2	20.37	5.6	214.	36.48	******
)	0/18:02:2	37:00	221.8	0.101	1.18	e M	2782	* ·	20.60	3.2	202	36.51	396-66
,	•	37:00	ž	0.092	4.98	10.0	5647	# P	20.76	J. 4	214.	36.55	99.862
	0.25	37:00	190.0	0.005	4.92	9•9	6347	7 M	20**02	9.	206.	36.41	99-85x
J	0 (37:00	257.1	0.138	1.72	2.5	3932	41.4	19.95	2.7	198.	36.53	99.92%
	7:0:01/0	37:00	273.8	0.070	7.69	3.9	7652		20.46	6.0	193.	36-51	386.66
,	30/18:03:45	20.00	303.8	0.267	7.34	5.4	9157	-1.3	19.63	e 0	228	36.61	34°64
,	: 2	200	7,001	0.131	12.63	8.8	12967.	0	19.72	- H	208	36.66	88*88
	30/18:04:14		258.2	0.020	9.22	ភ ភ	11632.	9.0	18.64	0 M	206.	36.71	296.66
-	30/18:04:26	37:00	23.000	0.00	e (n,	7322.	0.6	19.61	4	• 122	36.71	99.95%
)	30/18:04:39	37:00	223.3	100.0	7.07	11.9	5232	9*0	19.99	5.0	000	36.69	99.02% 00.00
	30/18:04:51		210.5	0.000	40.1		4917.	4.0	20.06	3.7	195	36.46	19/166
J	2	37:00	195.5	003	1-24	1 × 0	5732	-0-1	20.20	3.9	223.	36.57	X07 - 66
)	30/18:05:20	37:00	188.3	- 009	0-41	10.4	1050	-0-3	20.33	4.2	215.	36.53	400.00
	30/18:05:32	37:00	180.2	0.046	0.06	9	1332	•	20.47	4.4	213.	36.55	99.81
į	50/18:05:44	37:00	185.8	0.093	0.72	2.7	1727	0 0	20.58	₽	224.	36.58	30°-66
	30/18:05:56	37:00	205.4	0.004	2.80		4460		20.51	3.7	223.	36.51	99.892
	30/18:06:13	37:00	289.1	0.132	3.39	0.6	\$2.2¢		20.24	0 • •	217.	36.55	99.89x
ر ر	30/18:06:23	37:00	242.4	0.123	8.86	1.2	8487.	5.1.	61.07	e (206.	36.56	100.01x
	30,10,00,08	7	72	0.015	8.01	1.7	9262		10.05	× • •	194.	36.46	100.001
	30/18:02:05	,	292.6	0.159	4.94	2.3	7312.	6.0-	19.50	, ,	219.	36.41	866.66
į	30/18:07:19	, ,	241.0	0-113	10.26	-2.2	10647.	-0-7	19.01	7.6	207.	36.40	386*66
	30/18:07:31		7000	181.0	11.57	-1.5	12027.	-0.8	18.94	16 10 10 10 10 10 10 10 10 10 10 10 10 10	- 17	36.67	100.03%
	30/18:07:43		0 K	0.216	17.08	6.0-	16557.	-0.5	18.20	2.6	- 202	36.81	100.02X
)	30/18:07:55		473.1	0.240	19-01	M (19732.	-0-5	17.61	2.9	999	37.01	100.01%
	30/18:08:12	37:06	382.2	0.116	15.17	N (22267	1.7	17.16	3.7	223	37.03	166°66
	30/18:08:24		386.8		70.01	- 6	18787	2•2	17.56	2.9	202	11.11	196.66
)	30/18:08:37		418.1	0.108	60.10	2002	14212.	2.0	18.38	2.9	225	37.19	****
	30/18:08:49		402.1	0.164	9.54	4 4	11617	۲۰۰	19.25	3.1	215.	37,17	99.55
)	30/18:09:05		425.2	0.178	11.72	41.3	13552	: -	19.29	2.5	202.	37.34	99.57%
	20/18:09:18		492.9	0.269	14.38	28.0	15462.		* 0 * 0 *	• • • • • • • • • • • • • • • • • • •	203.	37.54	X69.66
	30/18:09:30	37:06	493.7	0.720	24-20	19.1	22712.	2.6	17-46	× • • • • • • • • • • • • • • • • • • •	202	37.66	99.81%
•	30/18:00:04		454.2	0.701	26.47	23.0	26847.	0.8	16.23	,	193	37.55	X06*66
	30/18:10:11		39304	0.0266	18.35	21.6	22017.	10.6	16.83		101	37.33	99.88x
		20.4	400.0	***	6.92	37.4	12767.	10.3	18.71	•		14.75	99.85%
`	0/18:1	37:06	276.5	797.0	9.50	52.7	12527.	9.1	18.95	17	251.	31043	99.638
	3:10	37:06	293.7	750-0	6.24		10692.	0 .	19.08	5.1	235.	37.40	71C-66
1	3:11	37:06	274.4	0.030	77.6	2 4 4 4 4 4 4 4 4 4 4 4 4 4 4 4 4 4 4 4	3281.	7.0	19•35	3.7	207.	37.28	774458
	8:11	:	256.0	0.021	6.0		3727	6.1	19.88	4 •5	204.	37-18	90.00
	3:11:2	::	306.2	0.017	0.21	0.46	2010	,	20.23	3.2	187.	37.07	99.014
-	:11	~	276.7	0.141	4 8 4	91.1	4467	?,	20.42	3.4	198.	37.08	98.784
	:11:5	37:06	247.4	0.034	7.54	16.0	7427		20.34	3.9	192.	37.06	99.478
						;	• • • • • • • • • • • • • • • • • • • •	1.0	17.44	4.2	218.	37.02	99.76X
7				•									: ;

PAGE 2

	* * * * * * * * * * * * * * * * * * *	99.69%	99.59%	99.532	365-66 200 00	99.86%	100-96%	¥06.66	*****
AMBTENT	TEMP (C)	37-15	37.03	37.10	37.16	37.15	37.12	36.96	
â	(DEG)	220.	204.	224.	233.	224.	199.	200.	
SH	(MPH)	4.4	. S.	m e	9 0	30.00	5.2	3.7 2.9	
05	(x)	19.78 20.18	20.38	20.53	20.08	20-17	20.49	20.33	
	- 40	1.6	1.5 5.4	n.0	0.0	7-0-	8 0 0 T		
	5,407	3347	2522.	1212.	3797.	1777.	1412.	2192.	
РРМ	14.4	12-1	. 9 . 8	9•6	D M	*	2.7	0.0	
XON	2.48	1.16	0.25	90.0	1-67	0.55	1.24	1.64	
202	0.014	0.014	0.005	0.030	0.001	0.003	0.043	C 0 0 0	
PROBE TEMP (C)	228.0	202.4	189.5	173.7	165.3	168.5	171.5		
PROBE HGT(FT)	37:06	37:06	37:06	37:06	37:06	37:06	37:06		
TINE	30/18:12:10	30/18:12:35	30/18:12:59	30/18:13:16	30/18:13:28	30/18:13:53	30/18:14:22		

TEST B1 STATISTICAL SUMMARY

COMBUSTION	6.40 1.07	0.5	26	
AMBIENT	36.9	• 0	- 83	į
ND (DEG)	209.	14.	59	185
SH SH	3.7	6.0	59	9.0
THC (PPM)	1.2	3.1	59	5.7
C02 (PPH)	7982.	6324.	83 6	423.
CO CPPM)	12.8	15.5	,	2.5
02 (PCT)	19.57	, or	20.43	4
NOX (PPA)	6.37	59	0.84	
\$02 (PPH)	0-141	59	0.027	
PROBE SO2 TEMP(C) (PPH) AVERAGE 276.0 0.105	96.5	59	42.0	
AVERAGE	STANDARD DEVLATION	NUMBER OF OBSERVATIONS	AVERAGE BACKGROUND	

MEASUREMENTS	CHILLIAN
AMBIENT	
BACKGROUND	

	TIME END 20/17:48:34
	TIME BEGIN 30/17:41:20 30/18:19:38
1 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	BACKGROUND FILE BACKGROUND 43 BACKGROUND 44

magneticities and the telephone and the

Alternative Monitoring Methods

Alternative Monitoring Methods

The monitoring of control devices subject to 40 CFR Subparts are generally applicable to §60.13(i) and §63.8(f). As stated in 40 CFR §63.8(f)(2):

The Administrator may approve alternatives to any monitoring methods or procedures of this part...

Related to alternative monitoring, 40 CFR §63.8(f)(4) states:

The application must contain a description of the proposed alternative monitoring system which addresses the four elements contained in the definition of monitoring in §63.2 and a performance evaluation test plan, if required, as specified in paragraph (e)(3) of this section...

The four elements of the 40 CFR §63.2 definition of monitoring are: indicator of performance, measurement technique, monitoring frequency, and averaging time.

ExxonMobil proposes the following alternative monitoring methods:

- 1. Monitor and record the line pressure to the MPGF when there is waste gas routed to the MPGF to ensure the line pressure exceeds 4 psig at operating temperature over a one-hour block average;
- 2. Monitor and record the net heating value of the vent gas sent to MPGF using an on-line analyzer system when there is waste gas routed to the MPGF;
- 3. Maintain, with the addition of supplemental fuel as necessary, a minimum net heating value of 800 Btu/scf of the vent gas (adjusted for hydrogen) over a one-hour block average when there is waste gas routed to the MPGF system; and
- 4. Monitor and maintain at least one operating pilot flame on each stage/runner of the MPGF when there is waste gas routed to the MPGF system.

Indicator of performance – The pressure and heating value constraints above are the operating ranges over which combustion performance of the MPGF has been found to be optimum in the past. In addition, John Zink has guaranteed performance of the MPGF's burners over the operating range in a letter included as Attachment 5.

Measurement technique – The pressure in the vent header will be known through input from pressure transmitters and staging will be computer-controlled.

The heating value of the vent gas will be calculated from composition data which will be determined through GC and/or calorimeters. Most waste gas streams that will be routed to the MPGF will consistently have a net heating value in excess of 800 Btu/scf, but there may be a few instances where the waste gas will contain appreciable quantities of hydrogen. It is widely known that hydrogen contributes to good combustion more than its volumetric net heating value of 274 Btu/scf would imply. Most notably, hydrogen contributes to good combustion as a result of a high flame speed. In an effort to address this consideration, an adjustment to the volumetric heating value of hydrogen is made when calculating the net heating value of waste gas streams routed to flares. This net heating value of hydrogen makes to the good combustion of waste gas streams routed to flares.

¹ The most recent example of this adjustment to the net heating value of hydrogen is contained in the United States of America v. Marathon Petroleum Company LP and Cattlesburg Refining, LLC Consent Decree signed April 5, 2012. The "net heating value of hydrogen as adjusted" discussion is contained in Section III Definitions and Appendix 1.3: http://www.epa.gov/compliance/resources/decrees/civil/caa/marathonrefining-cd.pdf

Monitoring frequency - Except for periods of system malfunction, repairs, calibration checks, periodic maintenance, and zero and span adjustments as required, all continuous monitoring systems shall be capable of monitoring and recording at least four data points per hour (continuous operation).

Averaging time – Hourly vent gas header pressure will be monitored and recorded on a fifteen-minute block basis when the MPGF is in operation. Hourly net heating values will be determined by GC and/or calorimeter on a fifteen-minute block basis when the MPGF is in operation.

The alternative monitoring methods proposed in this equivalency determination meet the four elements of the §63.2 definition of monitoring. ExxonMobil proposes that operation of the MPGF within the operating parameters above is considered equivalent to compliance with 40 CFR §60.18, or 40 CFR §63.11.

Please note that if a lower pressure and/or lower heating value can be demonstrated to achieve the same level of combustion efficiency through vendor tests, industry studies, calculations, etc., then these lower limits will be documented and implemented.

A performance evaluation test plan is impractical to conduct at the site due to the amount of waste gas that would need to be generated for the test and the means of generating it. A test conducted at the site could also pose significant safety concerns in terms of data collection.

Vendor Guarantee



International Headquarters PO Box 21220 Tulsa, OK 74121-1220 918/234-1800

November 5, 2012

Subject:

LRGO Multi-Point Ground Flares

Flare Burner Emissions Guarantees

Ref:

Baytown Olefins Plant.

Dear Sir / Madam:

John Zink Co has reviewed the processes/stream data provided by ExxonMobil for the proposed new Unit at the Baytown Olefins Plant. We confirm that the John Zink LRGO Multi-Point Ground Flare system is our recommended flare design to provide high efficiency 100% smokeless flaring in this service.

Based on our review of the process data, John Zink confirms our performance guarantee of the proposed ground flare burners as follows. We guarantee the hydrocarbon destruction efficiency to be 99.8% or greater in the following range of operation:

Burner operating pressure > 4 psig, and

Flare gas net heating value > 800 BTU/SCF

This 4 psig value would be above our de-stage pressure that we use to stage LRGO ground flare burners and the minimum 800 BTU/SCF is below the heating value of all of the streams identified in the processes/stream data provided by ExxonMobil. There is a separate elevated flare that will be used as a first stage to flare the low flow and/or low BTU streams outside this range of operation.

We understand that the proposed streams to the ground flare might include hydrogen. It is well accepted that hydrogen contributes to better combustion more than its volumetric heating value would imply, most notably as a result of a high flame speed and low stoichiometric air requirement. When hydrogen is present in the flare gas, its heating value shall be considered at an 'adjusted' value in calculation of the flare gas heating value, as has been used in the past.

E4.JOHN ZINK.

If you have any additional questions or comments please feel free to contact us.

Best Regards,

Kevin Leary

Applications Engineering Director Flare Systems

Kin Ling

John Zink Co LLC



International Headquarters PO Box 21220 Tulsa, OK 74121-1220 918/234-1800

November 5, 2012

Subject:

LRGO Multi-Point Ground Flares

Flare Burner Emissions Guarantees

Ref:

Mont Belvieu Plastics Plant.

Dear Sir / Madam:

John Zink Co has reviewed the processes/stream data provided by ExxonMobil for the proposed new Unit at the Mont Belvieu Plastics Plant We confirm that the John Zink LRGO Multi-Point Ground Flare system is our recommended flare design to provide high efficiency 100% smokeless flaring in this service.

Based on our review of the process data, John Zink confirms our performance guarantee of the proposed ground flare burners as follows. We guarantee the hydrocarbon destruction efficiency to be 99.8% or greater in the following range of operation:

Burner operating pressure > 4 psig, and

Flare gas net heating value > 800 BTU/SCF

This 4 psig value would be above our de-stage pressure that we use to stage LRGO ground flare burners and the minimum 800 BTU/SCF is below the heating value of all of the streams identified in the processes/stream data provided by ExxonMobil. There is a separate elevated flare that will be used as a first stage to flare the low flow and/or low BTU streams outside this range of operation.

We understand that the proposed streams to the ground flare might include hydrogen. It is well accepted that hydrogen contributes to better combustion more than its volumetric heating value would imply, most notably as a result of a high flame speed and low stoichiometric air requirement. When hydrogen is present in the flare gas, its heating value shall be considered at an 'adjusted' value in calculation of the flare gas heating value, as has been used in the past.

KO JOHN ZINK.

If you have any additional questions or comments please feel free to contact us.

Best Regards,

Kevin Leary

Applications Engineering Director Flare Systems

Kuin Luy

John Zink Co LLC